

## PROPOSAL 8-4 (2009)

---

**SCOPE: Sec. 13.6.5.5 of the 2008 Provisions**

---

### PROPOSAL FOR CHANGE:

1 **Revise the following Sec. 13.6.5.5:**

2  
3 **13.6.5.5** 6. f. Attachments into concrete utilize ~~nonexpanding insets, power~~  
4 ~~actuated fasteners, or cast iron embedments~~ anchors that have not  
5 been prequalified for seismic applications in accordance with ACI  
6 355.2.

7  
8 **Commentary to Support Proposal 8-4**

9  
10 **Add the following as a separate paragraph at the end of the section to the Chapter 13**  
11 **C13.6.5.5 Commentary:**

12  
13 The previous language in Item 6f was intended to identify anchor types that  
14 would be considered non-ductile. The previous requirement has been superseded  
15 by requirements for qualification that include checks for ductility and good  
16 performance in earthquake conditions.  
17

18  
19  
20 **REASON FOR PROPOSAL:**

21  
22 The existing language was intended to identify anchor types that would be  
23 considered non-ductile. It has been superseded by requirements for qualification  
24 that include checks for ductility and good performance in earthquake conditions.  
25  
26  
27