

PROPOSAL 4-6 (2009)

SCOPE: Part 3 of the 2009 Provisions

PROPOSAL FOR CHANGE:

1 **Delete from Part 3 of the 2009 Provisions the Appendix to Chapter 9 and**
2 **Commentary “Untopped Precast Diaphragms.**

REASON FOR PROPOSAL:

3
4
5
6 This Appendix was added first in the *1997 Provisions* and was aimed at describing a
7 methodology that could address some of the perceived vulnerability issues for the performance
8 of precast concrete floor systems in the 1994 Northridge earthquake. The performance based
9 methodology described in the white paper of Proposal 4-5 is more comprehensive, more rigorous
10 and is applicable nationwide. The Appendix needs to be withdrawn if proposal 4-5 passes.
11
12
13
14
15
16
17