

PROPOSAL 8-4 (2009)

SCOPE: Sec. 13.6.5.5 of the 2008 Provisions

PROPOSAL FOR CHANGE:

1 **Revise the following Sec. 13.6.5.5:**

2
3 **13.6.5.5** 6. f. Attachments into concrete utilize ~~nonexpanding insets, power~~
4 ~~actuated fasteners, or cast iron embedments~~ anchors that have not
5 been prequalified for seismic applications in accordance with ACI
6 355.2.
7

REASON FOR PROPOSAL:

8
9
10 The existing language was intended to identify anchor types that would be
11 considered non-ductile. It has been superseded by requirements for qualification
12 that include checks for ductility and good performance in earthquake conditions.
13

TS 8 VOTE:

14 Soules – Y

15 Lama – Y

16 Bachman – Y

17 Caldwell – Y

18 Dowty – Y

19 Silva – Y

20 Soulages – Y

21 Malushte – Y

22 Gillengerten – Y

23 Sprague – Y

24 Haupt – Y

25
26 Lake – NV

27
28
29 I am giving Jim a free pass of this set of proposals since he is just joining TS-8 to replace Chris.
30
31 Dubai.

32
33 Azzi – Y