

# PROPOSAL 4-1 (2009)

---

## SCOPE: Chapter 23 Seismic Design Reference Documents Sec. 23.1

---

### PROPOSAL FOR CHANGE:

1 **Revise the following entry within Sec. 23.1 to Part 1 of the 2009 Provisions:**

2  
3 **ACI**  
4 **American Concrete Institute**  
5 **P.O. Box 9094**  
6 **Farmington Hills, MI 48333-9094**  
7

8 **ACI 318**  
9 Sections 14.2.2, 14.2.2.1, 14.2.2.2, 14.2.2.3, 14.2.2.4, 14.2.2.5, 14.2.2.6, 14.2.2.7,  
10 14.2.2.8, 14.2.2.9, 14.2.3, 14.2.3.1.1, 14.2.3.2.1, 14.2.3.2.2, 14.2.3.2.3, 14.2.3.2.5,  
11 14.2.3.2.6.  
12 *Building Code Requirements for Structural Concrete, 2008*  
13

### REASON FOR PROPOSAL:

14  
15  
16 To change the reference document from ACI 318-05 to ACI 318-08 and permit the elimination  
17 of many of the exceptions to ACI 318-05 contained within ASCE/SEI 7-05 Sec. 14.2. The  
18 sections listed correspond to those now listed in Proposals 4-2 and 4-3. No listing of changes  
19 has been made for ACI 318 references outside of TS-4's jurisdiction.  
20

21 **TS-4 VOTE:** In a ballot canvassed on 12/14/17 the following vote was recorded.

22  
23 *YES= 9                      Yes with Reservations =1      No= 0                      Not Voting= 1*

24  
25 *Changes were made to the reason statement to address the concern of the Y/R voter.*  
26  
27  
28  
29  
30  
31  
32