

## PROPOSAL 4-6 (2009)

---

**SCOPE: Part 3 of the 2009 Provisions**

---

### PROPOSAL FOR CHANGE:

1 **Delete from Part 3 of the 2009 Provisions the Appendix to Chapter 9 and**  
2 **Commentary “Untopped Precast Diaphragms.**

### REASON FOR PROPOSAL:

3  
4  
5  
6 This Appendix was added first in the *1997 Provisions* and was aimed at describing a  
7 methodology that could address some of the perceived vulnerability issues for the performance  
8 of precast concrete floor systems in the 1994 Northridge earthquake. The performance based  
9 methodology described in the white paper of Proposal 4-5 is more comprehensive, more rigorous  
10 and is applicable nationwide. The Appendix needs to be withdrawn if proposal 4-5 passes.

11  
12 **TS-4 VOTE:** In a ballot closing 12/14/2007 TS-4 voted as follows:

13  
14 *YES = 9*      *Yes with Reservations = 0*      *No = 0*      *Not Voting = 2*  
15  
16  
17  
18  
19  
20  
21